



# City of Austin

## PUBLIC WORKS DEPARTMENT

Architectural Project Management Division

6800 Burleson Road, Building 312, Suite 200, Austin, Texas 78744

Phone (512) 974-7221 Fax (512) 974-7222

October 5<sup>th</sup>, 2020

**PROJECT: Cepeda Branch Library Renovation**

**CIP ID: 6014.041**

**IFB#: 6100 CLMC792**

**SUBJECT:** Answers to Bidders Questions as of the date of this letter.

**The following are answers to Bidders received on the above project. These answers do not modify the Contract. Any modifications to the Contract will be through Addenda**

Q-1: What Type of Recess Can goes in the Kiosk area? Not Specified – F.6 type?

A-1: Yes, F.6 type as shown on Electrical Lighting Plan, 1/Sheet E-2.0.

Q-2: The fixture count on the Architectural reflected ceiling plan (A2.0) does not match the counts on the Electrical Lighting plan (E2.0).

a. It looks like some of the fixture symbols were duplicated on the E-Sheets for F.6 and F.4, which count is correct?

A-2: The fixture symbols are duplicated on the Electrical Lighting Plan, Sheet E-2.0 – but locations are correct. The correct fixture count is three (3) F.4 type fixtures and seven (7) F.6 type fixtures.

Q-3: Are there any other sensors or controls being added for lighting other than the AS occupancy sensors in each bathroom (E-2.0)?

A-3: Besides the AS occupancy sensor in each bathroom, there is a VS type occupancy sensor mounted in the ceiling above the Circulation Desk as shown on the Electrical Lighting Plan, Sheet E-2.0.

Andrew Clements  
COA PWD APMD  
Project Manager